

**MANZANITA ROOM
CITY OF LAFAYETTE COMMUNITY CENTER
500 SAINT MARY'S ROAD
LAFAYETTE, CA 94549**

PROJECT NO. 012-9174

DOCUMENT 00 91 13

ADDENDUM NO. 3

The following clarifications, additions, and deletions shall become a part of the plans and specifications for the above project, and shall be bound by the General Conditions, Technical Specifications, and all other conditions of the Bid Documents.

PROJECT PLANS

1. Sheet A.001, Detail 4, "Building Data"- Fifth paragraph of notes under "Automatic Fire Protection System," reference to "7/A.001" shall be replaced with "1/A.102."
2. Sheet A.502, Detail 1, exterior concrete slab shown is reinforced, per A.202.
3. Sheet M2.0, Detail 2, location of central controller shall be in the "Foyer" west wall. See also E.101, electrical "Site Plan" for coordination.

CITY OF LAFAYETTE



Date: September 12, 2014

By: Tony Coe, City Engineer