

**MANZANITA ROOM  
CITY OF LAFAYETTE COMMUNITY CENTER  
500 SAINT MARY'S ROAD  
LAFAYETTE, CA 94549**

**PROJECT NO. 012-9174**

**RESPONSE TO PRE-BID RFI NO. 3**

**QUESTION:** Clarify if General Contractor is responsible to pay EBMUD connection fees.

**ANSWER:** There is no connection fee anticipated for domestic water supply, because existing water source is being re-used to supply the new building. A new private fire service connection is required for the fire sprinkler system. City will apply and pay fees for this service connection.

CITY OF LAFAYETTE



Date: September 30, 2014

By: Tony Coe, City Engineer