

**MANZANITA ROOM
CITY OF LAFAYETTE COMMUNITY CENTER
500 SAINT MARY'S ROAD
LAFAYETTE, CA 94549**

PROJECT NO. 012-9174

DOCUMENT 00 91 13

ADDENDUM NO. 9

The following clarifications, additions, and deletions shall become a part of the plans and specifications for the above project, and shall be bound by the General Conditions, Technical Specifications, and all other conditions of the Bid Documents.

PROJECT MANUAL

1. Section 03 30 00, "Cast-in-Place Concrete," Part 2, Paragraph 2.04.1.4.f, the reference to air entrainment is hereby deleted. Concrete does not require air entrainment.

CITY OF LAFAYETTE



Date: October 3, 2014

By: Tony Coe, City Engineer