

CITY OF LAFAYETTE
2021 SURFACE SEAL PROJECT, PROJECT # 014-9725

CLARIFICATION ADDENDUM #1
March 3, 2021

The following clarifications are provided in response to Requests for Information and questions submitted by bidders to date.

Section SP 21-02 Micro-Surfacing and Fiberized Micro-Surfacing of the Special Provisions indicates that the micro-surfacing and fiberized micro-surfacing shall conform to Section 10-5 of the Technical Provisions of the Standard Specifications.

“Section 10-5.2.2 Aggregates and Mineral Fillers – Aggregates and mineral fillers shall be based on a laboratory mix design submitted for approval by the Engineer prior to beginning of work. Both shall conform to Section 10-2.1.5 and 10-2.1.6 of these Technical Provisions”.

“Section 10-2.1.5 Aggregate – Aggregate shall consist of sound, durable, crushed stone or crushed gravel and approved mineral filler. The material shall be free from vegetation matter and other deleterious substances. **Aggregate shall be 100% crushed with no rounded particles, volcanic in origin and black in color, as supplied by George Reed, Table Mountain Plant, Sonora, CA, or approved equal.** The use of gray or light colored aggregate shall not be allowed.”

CITY OF LAFAYETTE

Date: March 3, 2021

/s/

By: Matt Luttrupp
Engineering Services Manager